

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT		BPA NO.	1. CONTRACT ID CODE	PAGE 1	OF 3		
2. AMENDMENT/MODIFICATION NO. A00002		3. EFFECTIVE DATE 01-23-2013		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable) 554-13-808	
6. ISSUED BY CODE Department of Veterans Affairs Network Contracting Office NCO 19 4100 E. Mississippi Avenue, Suite 900 Glendale CO 80246		7. ADMINISTERED BY (If other than Item 6) CODE Department of Veterans Affairs Network Contracting Office NCO 19 4100 E. Mississippi Avenue, Suite 900 Glendale CO 80246					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) To all Offerors/Bidders				(X)	9A. AMENDMENT OF SOLICITATION NO. VA259-13-R-0272		
					9B. DATED (SEE ITEM 11) 01-23-2013		
				X	10A. MODIFICATION OF CONTRACT/ORDER NO.		
					10B. DATED (SEE ITEM 13)		
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required) 554-3630162-2525-854200-3223 23NRMISC0							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
(X)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.						
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).						
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:						
	D. OTHER (Specify type of modification and authority)						
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return ¹ _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) a) Additional questions and answers were found that were received prior to the date required for submission are attached. Some additional remaining questions and answers are also included. b) The date set for the receipt of offers has not been changed.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Daniel J. Pagone V1912L3-4593			
15B. CONTRACTOR/OFFEROR (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED	
NSN 7540-01-152-8070 PREVIOUS EDITION NOT USABLE							
STANDARD FORM 30 (REV. 10-83) Prescribed by GSA - FAR (48 CFR) 53.243							

Additional Questions:

1. Regarding the roof-top exhaust fan on building 20

- a. Is it currently operational?

Vent only, no fan

- b. Does it need to be removed and reinstalled?

Yes

- c. Does it need to be replaced?

No

- d. Should the exhaust fan be removed and have the hole filled in (structure, deck, membrane)?

No

- e. Does the sheet metal cap (approximately 4ft x 4ft need to be removed and reinstalled?

Yes

- f. Does the sheet metal cap (approximately 4ft x ft) need to be replaced?

No

- g. If the fan is currently non-operational, please confirm that any electrical issues which may be cause of non-operation are not a part of this scope.

Vent only. No electrical items to the vent

2. Please confirm that the roof-top vent on building 15 will be reused.

Yes

3. Please confirm that all other protrusions will remain in place.

Yes

4. What is the structure of the existing roof and decking? Wood? Concrete? Other?

Bldg. 15, Concrete & Bldg. 20, Wood

5. Reference section 07 60 00 – 3, paragraph 1.5 B. Shop drawings.
- The paragraph requires shop drawings for gravel stop-fascia. Please clarify that gravel ballast is not a part of the EPDM roofing system, and that shop drawings for gravel stop fascia are not required.

Gravel Stop will not be required with fully adhered roof system, disregard.

- The paragraph requires shop drawings for gutter and conductors. The existing buildings do not have gutters and/or conductors. Please confirm that gutters and conductors are not included in the scope, and that shop drawings for gutters and conductors are not required.

Gutters and conductors are not part of this project, disregard.

- The paragraph requires shop drawings for expansion joints. Please confirm that for roofs the size of buildings 15 and 20 that no expansion joints are required, and that shop drawings for expansion joints are not required.

Expansion joints are not required

6. Will water be made available on site for water tests?

Water is available from Bldg. 8, just to the West

7. Is temp fencing required around buildings during work?

No

8. What shall be done with the existing ballast on the roof? Stockpiled on site or removed from site?

Removed from the site

9. Is the owner looking for a 5 yr workmanship warranty and a 5 year manufacturer warranty? Typically a two year workmanship warranty is issued and 5 -30 yr manufacturer warranty can be issued. Please indicate what is desired.

We are requiring a 5 year leak free warranty

10. Have plans been posted to the FBO site?

This project does not have drawings

11. How will it be determined if the site superintendent is OSHA competent or not? Is there a specific certification they will need.

The OSHA 30 hour certificate

12. Can the site super also be the OSHA competent person that needs to be on site?

Yes, with the OSHA 30 hour certificate

13. Does the gutter and downspout on bldg. 20 need to be replaced?

No